



Commonwealth of Massachusetts
Executive Office of Energy & Environmental Affairs

Department of Environmental Protection

Southeast Regional Office • 20 Riverside Drive, Lakeville MA 02347 • 508-946-2700

Charles D. Baker
Governor

Karyn E. Polito
Lieutenant Governor

Kathleen A. Theoharides
Secretary

Martin Suuberg
Commissioner

Innovative Technology Notice
Application Submitted Pursuant to Title 5, 310 CMR 15.000
Department of Environmental Protection
Wastewater Management Program
Transmittal Number: X285590
Application Filing Date: February, 2020

Public Notice is hereby given of the application by KleanTu LLC to the Department of Environmental Protection requesting **Certification for Provisional Use** for secondary treatment and enhanced nitrogen removal for **NitROE® Waste-water Treatment System** pursuant to **310 CMR 15.286** of Title 5. This provision of Title 5 describes the approval process for **Provisional Use** of innovative/ alternative technologies for the treatment and subsurface disposal of sewage from facilities regulated under Title 5.

The application proposes the use of alternative standards for the following provision in Title 5:

The **NitROE® Waste-water Treatment System** will meet or exceed the following effluent discharge requirements for facilities with design flows less than 2000 gpd:

Effluent Total Nitrogen (TN) concentration of 11 mg/l, Total Suspended Solids (TSS) concentration less than 30 mg/l and total Biological Oxygen Demand (BOD) of less than 30 mg/l.

The Department welcomes any interested parties to provide any relevant information concerning the performance of this technology to be considered in the review process. The Department will consider all data and written comments submitted within **21 days** after the publication of this notice in order to decide whether to grant approval pursuant to 310 CMR 15.000. To schedule a time to review the application or to obtain further information regarding this application please contact the Wastewater Management Program at (617) 292-5790. All written comments should be submitted to: Department of Environmental Protection, Wastewater Management IA Program, One Winter Street, 5th Floor, Boston, MA 02108.

If you wish notification of the Department's preliminary determination concerning this application, please send to the Department a written request with your comments, if any, within 21 days from the publication date of this Environmental Monitor.

Marybeth Chubb, Section Chief
Wastewater Management Program
MassDEP