



Massachusetts Department of Environmental Protection
Bureau of Waste Site Cleanup
IRA REMEDIAL MONITORING REPORT
MEASUREMENTS

BWSC105 -B

Pursuant to 310 CMR 40.0400 (SUBPART D)

Remedial System or Monitoring Program: of

Release Tracking Number

For each Point of Measurement, related to concentration indicate the highest concentration detected during the reporting period, of each oil, hazardous material and/or remedial additive.

For each Point of Measurement for pressure differentials, indicate the lowest pressure differential detected during the reporting period.

Point of Measurement	Date (mm/dd/yyyy)	Contaminant, Measurement and/or Indicator Parameter	Influent Concentration (where applicable)	Midpoint Concentration (where applicable)	(check one)		Check here, if ND/BDL	Permissible Concentration or Pressure Differential	Units	Within Permissible Limits? (Y/N)
					<input checked="" type="checkbox"/> Discharge	<input type="checkbox"/> GroundWater Concentration Pressure Differential				
SYSTEM	06/01/2017	PFOS	3.200	0.730	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.07	UG/L	YES
SYSTEM	06/01/2017	PFOA	0.110		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0.07	UG/L	YES
SYSTEM	06/15/2017	PFOS	3.300	1.800	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.07	UG/L	NO
SYSTEM	06/15/2017	PFOA	0.098		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0.07	UG/L	YES
SYSTEM	06/27/2017	PFOS	2.6		<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.07	UG/L	NO
SYSTEM	06/27/2017	PFOA	0.099		<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.07	UG/L	YES

Check here if any additional BWSC105 B, Measurements Form(s), are needed.