3225 MAIN STREET • P.O. BOX 226
BARNSTABLE, MASSACHUSETTS 02630

(508) 362-3828 • Fax (508) 362-3136 • www.capecodcommission.org

CAPE COD COMMISSION

April 28, 2017

Angela Gallagher
Site Remediation Section
Southeast Regional Office
Department of Environmental Protection
20 Riverside Drive
Lakeville, MA 02347

Re: WSA-4-26179
Immediate Response Action
PFOS/PFOA in Groundwater

Dear Ms. Gallagher:

This is the fifth IRA monthly status report for the IRA approved by the Department in a letter dated November 10, 2016.

A carbon exchange was conducted on April 13, 2017 as indicated in my last status report/remedial monitoring report. The system sample on April 15th indicates an influent concentration of 3,200 ng/ PFOS and below reporting limits for the effluent. The system pumped over 49 million gallons for the reporting period with a calculated 1.4 pounds of PFOS removed

Please contact me if you have any questions on this submittal.

Sincerely,

Tom Cambareri
Technical Services Director for Water Resources
LSP #3788

Cc: Gerard Martin, DEP-SERO

Jack Yunits, County Administrator