



**Massachusetts Department of Environmental Protection**  
*Bureau of Waste Site Cleanup*  
**IRA REMEDIAL MONITORING REPORT**  
**MEASUREMENTS**

BWSC105 -B

Pursuant to 310 CMR 40.0400 ( SUBPART D )

Remedial System or Monitoring Program:  of

Release Tracking Number

For each Point of Measurement, related to concentration indicate the highest concentration detected during the reporting period, of each oil, hazardous material and/or remedial additive.

For each Point of Measurement for pressure differentials, indicate the lowest pressure differential detected during the reporting period.

Point of Measurement	Date (mm/dd/yyyy)	Contaminant, Measurement and/or Indicator Parameter	Influent Concentration (where applicable)	Midpoint Concentration (where applicable)	(check one)		Check here, if ND/BDL	Permissible Concentration or Pressure Differential	Units	Within Permissible Limits? (Y/N)
					<input checked="" type="checkbox"/> Discharge	<input type="checkbox"/> GroundWater Concentration Pressure Differential				
SYSTEM	03/01/2017	PFOS	3.7	1.4	0.15	<input type="checkbox"/>	<input type="checkbox"/>	0.07	UG/L	NO
SYSTEM	03/23/2017	PFOS	3.8	2.0	0.16	<input type="checkbox"/>	<input type="checkbox"/>	0.07	UG/L	NO
SYSTEM	03/01/2017	PFOA	0.12	0.047	0.007	<input type="checkbox"/>	<input type="checkbox"/>	0.07	UG/L	YES
SYSTEM	03/23/2017	PFOA	0.087	0.071	0.010	<input type="checkbox"/>	<input type="checkbox"/>	0.07	UG/L	YES
SYSTEM	02/14/2017	PFOS	0.920	0.00	0.00	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.07	UG/L	NO
SYSTEM	02/16/2017	PFOS	2.800	1.000	0.025	<input type="checkbox"/>	<input type="checkbox"/>	0.07	UG/L	NO
SYSTEM	02/14/2017	PFOA	0.065			<input type="checkbox"/>	<input type="checkbox"/>	0.07	UG/L	NO
SYSTEM	02/16/2017	PFOA	0.088	0.039	0.005	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.07	UG/L	NO

Check here if any additional BWSC105 B, Measurements Form(s), are needed.